

Valeur des sondes des chaudières OERTLI

Sonde Extérieure (valeurs en ohms)				
Produits	Oetronic 3 & 4 FSC - FSB PLU - CLU Condens GMX 2000 Condens GVX 124 Condens	GMR 1000	REA	GMS 24
Température	AF 60 FM 46	AD 225	AF 200	
-20	2392	98932	1383	96124
-16	2088	82000	1434	
-12	1811	64000	1485	50000
-8	1562	60000	1537	
-4	1342	47000	1590	
0	1149	36129	1644	32504
4	984	30000	1699	
8	842	22500	1755	
12	720	21000	1812	
16	616	18000	1869	
20	528	14773	1928	12483
24	454	12000	2000	

Sonde Chaudière (valeurs en Ohms)				
Produits	Tableau X Oetronic 3 Oetronic 4 : Sondes circuits + ECS FSC - FSB - FS GVX 100 GMX 2000 MUR 224 / 324	<u>Sondes chaudière :</u> GMR 1000 GMR 3000 OSCR GMR 4000 & 5000 GSR 140-45-115 DPSM 2 GSR 230 Condens	REA	GMS 24
Température	Sonde NTC 10	Sondes chaudière	VF 202 KVT 20 & 40	Sonde CTN
-20	-	98932	1383	96124
-10	-	58879	1511	54931
0	32014	36129	1644	32504
10	19691	22804	1783	19853
20	12474	14773	1928	12483
25	10000	12000	2002	10000
30	8080	9804	2078	8060
40	5372	6652	2234	5332
50	3661	4607	2395	3607
60	2535	3252	2563	2491
70	1794	2337	2735	1753
80	1290	1707	2914	1256
90	941	1266	3098	-
100	-	952	3287	-
110	-	726	-	-